

Technical Bulletin

Product: Greenstar 1000 Combi NG

REVISED COMBUSTION DATA

The combustion data table in the Greenstar 1000 Combi installation and servicing manuals has been updated to reduce the required minimum difference between Max and Min combustion readings.

This revised tolerance can be applied retrospectively to all Greenstar 1000 appliances

To ensure correct combustion throughout the entire modulation range of these appliances, it is important that the minimum CO₂ reading is always less than the maximum CO₂ reading.

The combustion data table has previously stated that CO₂ on minimum output must be at least 0.5 lower than the maximum CO₂ reading.

This has now been amended to be at least 0.2 lower than the maximum CO₂ reading (See fig 1)

LPG combustion data is included in the revised manuals. This will become relevant once LPG conversion kits become available.

Appliance combustion settings		
CO ₂ Reading	O ₂ Reading	CO Reading
Natural Gas - Maximum rated output ¹⁾		
Between 8.6% and 10.5%	5.6 - 2.2	<250ppm
Natural Gas - Minimum rated output ¹⁾		
A minimum of 0.2 lower than the maximum reading taken, but above 8.1%	<6.1	<250ppm

1) Measured 10 minutes after firing the appliance

Appliance combustion settings		
CO ₂ Reading	O ₂ Reading	CO Reading
LPG - Maximum rated output ¹⁾		
Between 9.8% and 10.6%	6.0 - 4.8	<250ppm
LPG - Minimum rated output ¹⁾		
A minimum of 0.3 lower than the maximum reading taken, but above 9.3%	<6.8	<250ppm

1) Measured 10 minutes after firing the appliance

Fig 1

Whilst it is always our intention to fully assist, it is essential to recognise that all information given by the company in response to an enquiry of any nature is provided in good faith and based upon the information provided with the enquiry. We recommend that advice should always be checked with your installer or contract partner. Consequently, the company cannot be held responsible for any liability relating to the use or repetition of such information or part thereof. In addition, whilst making every reasonable effort to monitor the performance and quality of our supply, installation and service network, we do not accept responsibility for the workmanship or operation of any third party company that the company may have promoted either in conversation, e-mail, or other communication. Similarly, the views and opinions expressed in communication with individuals within the company may not reflect that of the business as a whole.

You can find this, and all issued technical bulletins on the Worcester website at: www.worcester-bosch.co.uk/tb
or www.worcester-bosch.ie/tb